

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/SCHOOL/2019/ 938

Dated: 3/5/19

FIRE SAFETY CERTIFICATE

Certified that Holy Child Senior Secondary School at Tagore Garden, New Delhi-110027 comprised of two blocks. 1st Block is Ground & Two Upper Floors & 2nd Block is Basement & Ground Floor only owned / occupied by Holy Child Senior Secondary School, has already been issued NOC / FSC by this department vide letter No. F6/DFS/MS/2016/WZ/393 dated 11/03/2016. The premises was re-inspected by the officer concerned of this department on 18.04.2019 in the presence of Sh. Prakashan (Administration) and observed that Fire prevention and fire safety arrangements provided in the premises, found in good working condition. The premises have therefore, deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by Director of Education Circular 262-362 dated 17/01/2005 and that the building / premises is fit for occupancy class Educational (Group B) with effect from 3/5/19.....for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 3/5/19 at New Delhi by.

Mellie
Principal
Holy Child Sr. Sec. School
Tagore Garden,
New Delhi-110027


(DHARAMPAL BHARDWAJ)
DY. CHIEF FIRE OFFICER.

Copy to :-

1. Principal, Holy Child Senior Secondary School, Tagore Garden, New Delhi-110027.
2. The Director of Education, GNCT of Delhi, Old Secretariat, Delhi-110054.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their' in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first